

Detailed Inventory																									
PWS Name: Texas A&M University-Commerce PWSID: 1160008																									
TCEQ-20943 (Rev. 1/17/2024)																									
Unique Service Line ID	Location Information							System-Owned Portion				Customer-Owned Portion			Entire Service Line Material Classification ¹	Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line	
	Street Number ¹	Street Name ¹	City ¹	Zip Code ¹	Other Location Identifier ²	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification ¹	If Non-Lead in Column J, Was Material Ever Previously Lead? ²	Service Line Installation Date ²	Notes	Customer-Owned Portion Service Line Material Classification ¹	Service Line Installation Date ²	Notes		Is there a Lead Connector? ²	Is there Lead Solder in the Service Line? ²	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.							Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstream/ customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown	For example, lead gooseneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead	Note: This information may be helpful for identifying lead tap monitoring locations.						
505	1702	Education Dr.	Commerce	75428	Ferguson Social Sciences	N33°14.606	W095°54.313	Non-Lead - Copper	Don't Know	Unknown	C-900 PVC	Non-Lead - Copper	Unknown	Cast Iron to Copper in building.	Unknown	No	No		Building	No	Unknown	No	Tier 5		
513	1701	Education Dr.	Commerce	75428	Heritage House	N33°14.557	W095°54.313	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
511	1601	Education Dr.	Commerce	75428	Talbot Hall of Languages	N33°14.660	W095°54.250	Non-Lead - Copper	Don't Know	Unknown	4" C-900 Main	Unknown - Likely Lead	Unknown	Cast Iron in building & some galvanized uner.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
508	1800	Lee St.	Commerce	75428	Whitley Gymnasium	N33°14.693	W095°54.387	Galvanized	Don't Know	Unknown	8" C-900 Main	Galvanized	Unknown	3" Galvanized to building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
532	1606	Hwy 24	Commerce	75428	Memorial Stadium	n33°14.763	W095°54.667	Non-Lead - Plastic	Don't Know	Unknown	PVC C-900 Schd. 40	Unknown - Likely Lead	Unknown	PVC to building then galvanized & copper.	Unknown	No	No		Building	No	Unknown	No	Tier 5		
537	1801	Lee St.	Commerce	75428	Young Education North	N33°14.668	W095°54.408	Non-Lead - Copper	Don't Know	Unknown	PVC - C-900 New main.	Non-Lead - Copper	Unknown	Copper to PVC to building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
539	1804	Lee St.	Commerce	75428	Field House	N33°14.696	W095°54.445	Non-Lead - Copper	Don't Know	Unknown	PVC C-900 new main.	Unknown - Likely Lead	Unknown	Copper to building-some galvanized in building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
563	2105	Bois D Arc	Commerce	75428	Wathena Temple Building	N33°14.562	W095°54.380	Non-Lead - Copper	Don't know	Unknown	PVC Schd. 40 main.	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
568	2100	Bois D Arc	Commerce	75428	Education South	N33°13.579	W095°54.380	Non-Lead - Copper	Don't Know	Unknown	C-900 main	Unknown - Likely Lead	Unknown	Copper to building & some galvanized inside.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
569	2005	University Dr.	Commerce	75428	Art	N33°14.602	W095°54.556	Non-Lead - Copper	Don't Know	Unknown	C-900 mMain	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
501	1805	Lee St.	Commerce	75428	Velma K. Waters Library	N33°14.669	W095°54.433	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Building	No	Unknown	No	Tier 5		
588	2109	Jackson St.	Commerce	75428	Bledsoe Hall	N33°14.307	W095°54.656	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
593	1600	Education Dr.	Commerce	75428	F-1 Co-op	N33°14.617	W095°54.242	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Copper feed to each building / galvanized inside	Unknown	No	No		Multiple Family Residence	No	Unknown	Yes	Tier 5		
594	1604	Education Dr.	Commerce	75428	F-2 Co-op	N33°14.615	W095°54.271	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Copper feed to each building / galvanized inside	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
595	1606	Education Dr.	Commerce	75428	F-3 Co-op	N33°14.623	W095°54.285	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Copper feed to each building / galvanized inside	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
596	1609	Lee St.	Commerce	75428	F-4 Co-op	N33°14.655	W095°54.273	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Copper feed to each building / galvanized inside	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
597	1605	Lee St.	Commerce	75428	F-5 Co-op	N33°14.653	W095°54.246	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Copper feed to each building / galvanized inside	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
598	1601	Lee St.	Commerce	75428	F-6 Co-op	N33°14.629	W095°54.233	Non-Lead - Copper	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Copper feed to each building / galvanized inside	Unknown	No	No		Multiple Family Residence	No	Unknown	Yes	Tier 5		
600	2501	W Halls Ave.	Commerce	75428	Craddock Hall	N33°14.326	W095°54.629	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper feed to building and copper inside.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
601	2500	Hwy 24	Commerce	75428	Fling Hall			Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper feed to each building/ galvanized inside.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
611	2115	Jackson St.	Commerce	75428	Neu Hall	N33°14.303	W095°54.675	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper feed to each building/ galvanized inside.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
616	2003	Jackson St.	Commerce	75428	Webster Hall	N33°14.343	W095°54.683	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper feed to each building/ galvanized inside.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
618	2001	Jackson St.	Commerce	75428	Wray Hall	N33°14.345	W095°54.656	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper feed to each building/ galvanized inside.	Unknown	No	No		Multiple Family Residence	No	Unknown	No	Tier 5		
669	2404	W Halls Ave.	Commerce	75428	West Halls Laundry West (Key Hole)	N33°14.629	W095°54.668	Non-Lead - Copper	Don't Know	Unknown	PVC Main	Non-Lead - Copper	Unknown	Copper feed to building.	Unknown	No	No		Building	No	Unknown	No	Tier 5		
620	2601	Hwy 24	Commerce	75428	Children's Learning Center (Sikes Hall)	N33°14.300	W095°54.771	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Building	No	Unknown	No	Tier 5		
619	2301	Hwy 24	Commerce	75428	Berry Hall	N33°14.424	W095°54.776	Non-Lead	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Cast Iron to building/ galvanized and copper inside.	Unknown	Don't Know	Don't Know		Multiple Family Residence	No	Unknown	No	Tier 5		
622	2501	Hwy 24	Commerce	75428	Watson Building (old Children's Museum)	N33°14.355	W095°54.771	Non-Lead	Don't Know	Unknown	Cast Iron/ C-900 Main	Non-Lead - Copper	Unknown	Copper in building.	Unknown	Don't Know	Don't Know		Building	No	Unknown	No	Tier 5		
628	2201	Hwy 24	Commerce	75428	Smith Hall	N33°14.533	W095°54.787	Unknown - Unlikely Lead	Don't Know	Unknown	Cast Tron Main.	Unknown - Likely Lead	Unknown	Cast Iron to building. Galvanized and copper inside.	Unknown	Don't Know	Don't Know		Multiple Family Residence	No	Unknown	Yes	Tier 5		
514	1809	Lee St.	Commerce	75428	Holiday Student Services	N33°13.670	W095°54.461	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main	Non-Lead - Copper	Unknown	Cast Iron to building. Galvanized and copper inside.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
630	1603	Education Dr.	Commerce	75428	Journalism	N33°14.599	W095°54.286	Non-Lead - Copper	Don't Know	Unknown	Cast Iron Main.	Non-Lead - Copper	Unknown	Copper to building. Galvanized and copper inside.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
632	2008	University Dr.	Commerce	75428	McDowell Administration	N33°14.615	W095°54.547	Non-Lead - Copper	Don't Know	Unknown	3" PVC Main	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
640	2001	Culver St.	Commerce	75428	Whitley Hall			Non-Lead	Don't Know	Unknown	C-900 Main	Unknown - Material Unknown	Unknown	Cast Iron to building. Copper inside/ some galvanized.	Unknown	Don't Know	Don't Know		Multiple Family Residence	No	Unknown	No	Tier 5		
522	2000	University Dr.	Commerce	75428	CJ Austin Engineering & Technology	N33°14.560	W095°54.525	Non-Lead - Copper	Don't Know	Unknown	PVC Main	Non-Lead - Copper	Unknown	Copper to building.	Unknown	No	No		Building	No	Unknown	Yes	Tier 5		
657	2101	University Dr.	Commerce	75428	Performing Arts Center	N33°14.616	W095°54.586	Non-Lead	Don't Know	Unknown	C-900 Main	Non-Lead	Unknown	Cast Iron to building. Copper inside/ some galvanized.	Unknown	Don't Know	Don't Know		Building	No	Unknown	Yes	Tier 5		
743	2300	W Neal St.	Commerce	75428	Employee Services			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building.	Non-Lead	No	No		Building	No	No	No			

685	2000	Walnut	Commerce	75428	New Pride Apartments Community Center	N33°14.398	W095°54.571	Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Building	No	No	Yes	Tier 5	
687	2000	Walnut	Commerce	75428	New Pride Apartments I			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
688	2000	Walnut	Commerce	75428	New Pride Apartments II			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
689	2000	Walnut	Commerce	75428	New Pride Apartments III			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
690	2000	Walnut	Commerce	75428	New Pride Apartments IV			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
691	2000	Walnut	Commerce	75428	New Pride Apartments V			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
692	2000	Walnut	Commerce	75428	New Pride Apartments VI			Non-Lead - Copper	No	Between 1989 and 2014	PVC Main	Non-Lead - Copper	Between 1989 and 2014	Copper to building, CPVC inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
701	2401	Hubbell Dr.	Commerce	75428	Cain Concession Stand	N33°14.398	W095°54.995	Non-Lead - Copper	No	Between 1989 and 2014	Cast Iron Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to building.	Non-Lead	No	No		Building	No	No	No	Tier 5	
698	2350	Hwy 24	Commerce	75428	Morris Recreation Center	N33°14.406	W095°54.725	Non-Lead - Copper	No	Between 1989 and 2014	PVC Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to building.	Non-Lead	No	No		Building	No	No	Yes	Tier 5	
699	2201	W Neal St.	Commerce	75428	Keith D. McFarland Science Building	N33°14.548	W095°54.516	Non-Lead - Copper	No	Between 1989 and 2014	C-900 Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to building.	Non-Lead	No	No		Building	No	No	Yes	Tier 5	
710	1706	Stonewall	Commerce	75428	Alumni Center	N33°13.571	W095°54.360	Non-Lead - Copper	No	Between 1989 and 2014	Cast Iron Main.	Non-Lead	Between 1989 and 2014	Copper in building.	Non-Lead	No	No		Building	No	No	No	Tier 5	
727	1614	MSC Dr.	Commerce	75428	Art Sculpture Lab/Post Office			Non-Lead - Copper	No	Between 1989 and 2014	Black 2" Poly feed	Non-Lead - Copper	Between 1989 and 2014	Copper to building/ Galvanized & PEX inside.	Non-Lead	No	No		Building	No	No	No	Tier 5	
728	1611	W Neal St.	Commerce	75428	Football Locker Room (T-Lounge)			Non-Lead - Copper	No	Between 1989 and 2014	C-900 Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to/ in building.	Non-Lead	No	No		Building	No	No	No	Tier 5	
709	2100	University Dr.	Commerce	75428	New Music Building			Non-Lead - Copper	No	Between 1989 and 2014	C-900 Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to building.	Non-Lead	No	No		Building	No	No	Yes	Tier 5	
731	2513	W Halls Ave.	Commerce	75428	Pride Rock Hall			Non-Lead - Copper	No	Between 1989 and 2014	C-900 Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to building.	Non-Lead	No	No		Building	No	No	No		
742			Commerce	75428	Concession Building Stadium			Non-Lead - Copper	No	Between 1989 and 2014	C-900 Main.	Non-Lead - Copper	Between 1989 and 2014	Copper to & inside.	Non-Lead	No	No		Building	No	No	No	Tier 5	
744	2501	W Neal St.	Commerce	75428	Phase II Housing			Non-Lead - Copper	No	Between 1989 and 2014	Copper & cast iron to building	Non-Lead - Copper	Between 1989 and 2014	Copper & PEX inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
774	2401	W Hubbell Dr.	Commerce	75428	Soccer & Softball Locker Room			Non-Lead - Copper	No	After 2014	PVC Main.	Non-Lead - Copper	After 2014	Copper to and inside both.	Non-Lead	No	No		Building	No	No	No	Tier 5	
799	2400	Hwy 24	Commerce	75428	Phase III Housing			Non-Lead - Copper	No	After 2014	Copper & cast iron to building	Non-Lead - Copper	After 2014	Copper & PEX inside.	Non-Lead	No	No		Multiple Family Residence	No	No	No	Tier 5	
804	2201	Jones Rd.	Commerce	75428	Tennis Courts Building			Non-Lead - Copper	No	After 2014	PVC Main.	Non-Lead - Copper	After 2014	Copper to & inside building.	Non-Lead	No	No		Building	No	No	No	Tier 5	
805			Commerce	75428	Sand Volleyball Building			Non-Lead - Copper	No	After 2014	PVC Main.	Non-Lead - Copper	After 2014	Copper to & inside building.	Non-Lead	No	No		Building	No	No	No	Tier 5	
822	2210	Hwy 24	Commerce	75428	Nursing & Health Sciences Building			Non-Lead - Copper	No	After 2014	PVC Main.	Non-Lead - Copper	After 2014	Copper to & inside building.	Non-Lead	No	No		Building	No	No	No	Tier 5	
840	2104	University Dr.	Commerce	75428	New Welcome Center			Non-Lead - Copper	No	After 2014	PVC Main.	Non-Lead - Plastic	After 2014	Copper to building.	Non-Lead								Tier 5	